



WPDES PERMIT

STATE OF WISCONSIN
DEPARTMENT OF NATURAL RESOURCES
**PERMIT TO DISCHARGE UNDER THE WISCONSIN POLLUTANT DISCHARGE
ELIMINATION SYSTEM**

VILLAGE OF GLEN FLORA

is permitted, under the authority of Chapter 283, Wisconsin Statutes, to discharge from a facility
located at

INTERSECTION OF PRENTICE AND THIRD STREET, GLEN FLORA, WISCONSIN
to

**EFFLUENT DITCH TO DEER TAIL CREEK WITHIN THE DEER TAIL CREEK WATERSHED IN THE
UPPER CHIPPEWA RIVER BASIN IN RUSK COUNTY**

in accordance with the effluent limitations, monitoring requirements and other conditions set
forth in this permit.

The permittee shall not discharge after the date of expiration. If the permittee wishes to continue to discharge after this expiration date an application shall be filed for reissuance of this permit, according to Chapter NR 200, Wis. Adm. Code, at least 180 days prior to the expiration date given below.

State of Wisconsin Department of Natural Resources
For the Secretary

By _____
Tom Aartila
Upper Chippewa Watershed Program Supervisor, Northern Region

Date Permit Signed/Issued for Modification

PERMIT TERM: EFFECTIVE DATE - April 01, 2008

EXPIRATION DATE - March 31, 2013

EFFECTIVE DATE OF MODIFICATION: January 01, 2010

TABLE OF CONTENTS

1 INFLUENT REQUIREMENTS	1
1.1 SAMPLING POINT(S)	1
1.2 MONITORING REQUIREMENTS	1
1.2.1 <i>Sampling Point 701 - INFLUENT TO PLANT</i>	1
2 SURFACE WATER REQUIREMENTS	2
2.1 SAMPLING POINT(S)	2
2.2 MONITORING REQUIREMENTS AND EFFLUENT LIMITATIONS	2
2.2.1 <i>Sampling Point (Outfall) 001 - EFFLUENT</i>	2
3 SEPTAGE MANAGEMENT REQUIREMENTS	5
3.1 SAMPLING POINT(S)	5
3.2 RECORD KEEPING REQUIREMENTS AND LIMITATIONS	5
3.2.1 <i>Sampling Point 990 - Septic tank</i>	5
4 SCHEDULES OF COMPLIANCE	6
4.1 AMMONIA EFFLUENT LIMITS & FACILITY MODIFICATIONS	6
5 STANDARD REQUIREMENTS	7
5.1 REPORTING AND MONITORING REQUIREMENTS	7
5.1.1 <i>Monitoring Results</i>	7
5.1.2 <i>Sampling and Testing Procedures</i>	7
5.1.3 <i>Recording of Results</i>	7
5.1.4 <i>Reporting of Monitoring Results</i>	8
5.1.5 <i>Compliance Maintenance Annual Reports</i>	8
5.1.6 <i>Records Retention</i>	8
5.1.7 <i>Other Information</i>	9
5.2 SYSTEM OPERATING REQUIREMENTS	9
5.2.1 <i>Noncompliance Notification</i>	9
5.2.2 <i>Flow Meters</i>	9
5.2.3 <i>Raw Grit and Screenings</i>	9
5.2.4 <i>Sludge Management</i>	9
5.2.5 <i>Prohibited Wastes</i>	10
5.2.6 <i>Unscheduled Bypassing</i>	10
5.2.7 <i>Scheduled Bypassing</i>	10
5.2.8 <i>Proper Operation and Maintenance</i>	11
5.3 SURFACE WATER REQUIREMENTS	11
5.3.1 <i>Permittee-Determined Limit of Quantitation Incorporated into this Permit</i>	11
5.3.2 <i>Appropriate Formulas for Effluent Calculations</i>	11
5.3.3 <i>Visible Foam or Floating Solids</i>	11
5.3.4 <i>Percent Removal</i>	11
5.3.5 <i>Fecal Coliforms</i>	12
5.3.6 <i>Seasonal Disinfection</i>	12
5.3.7 <i>Applicability of Alternative Wet Weather Mass Limitations</i>	12
5.3.8 <i>Whole Effluent Toxicity (WET) Monitoring Requirements</i>	12
5.3.9 <i>Whole Effluent Toxicity (WET) Identification and Reduction</i>	12
5.4 LAND APPLICATION REQUIREMENTS	13
5.4.1 <i>Land Application Report for Septage</i>	13
5.4.2 <i>Other Methods of Disposal or Distribution Report for Septage</i>	13
5.4.3 <i>Approval to Land Apply Septage</i>	13
5.4.4 <i>Land Application Site Evaluation for Septage</i>	13
5.4.5 <i>Septage Hauling</i>	13
6 SUMMARY OF REPORTS DUE	14

1 Influent Requirements

1.1 Sampling Point(s)

Sampling Point Designation	
Sampling Point Number	Sampling Point Location, WasteType/Sample Contents and Treatment Description (as applicable)
701	Representative samples shall be collected from the metering manhole immediately following the final septic tank.

1.2 Monitoring Requirements

The permittee shall comply with the following monitoring requirements.

1.2.1 Sampling Point 701 - INFLUENT TO PLANT

Monitoring Requirements and Limitations					
Parameter	Limit Type	Limit and Units	Sample Frequency	Sample Type	Notes
Flow Rate		MGD	Daily	Total Daily	
BOD ₅ , Total		mg/L	2/Month	Grab	
Suspended Solids, Total		mg/L	2/Month	Grab	

2 Surface Water Requirements

2.1 Sampling Point(s)

Sampling Point Designation	
Sampling Point Number	Sampling Point Location, WasteType/Sample Contents and Treatment Description (as applicable)
001	Representative samples shall be collected from the sampling tap following the disinfection unit for all parameters except to measure the flow rate.

2.2 Monitoring Requirements and Effluent Limitations

The permittee shall comply with the following monitoring requirements and limitations.

2.2.1 Sampling Point (Outfall) 001 - EFFLUENT

Monitoring Requirements and Effluent Limitations					
Parameter	Limit Type	Limit and Units	Sample Frequency	Sample Type	Notes
Flow Rate		MGD	Continuous	Continuous	
BOD ₅ , Total	Weekly Avg	45 mg/L	2/Month	Grab	This limit is in effect from November through April annually.
BOD ₅ , Total	Weekly Avg	18 mg/L	2/Month	Grab	This limit is in effect from May through October annually.
BOD ₅ , Total	Monthly Avg	30 mg/L	2/Month	Grab	This limit is in effect from November through April annually.
BOD ₅ , Total	Monthly Avg	18 mg/L	2/Month	Grab	This limit is in effect from May through October annually.
BOD ₅ , Total	Weekly Avg	2.0 lbs/day	2/Month	Calculated	This limit is in effect from May through October annually.
Suspended Solids, Total	Monthly Avg	30 mg/L	2/Month	Grab	This limit is in effect from November through April annually.
Suspended Solids, Total	Monthly Avg	18 mg/L	2/Month	Grab	This limit is in effect from May through October annually.
Suspended Solids, Total	Weekly Avg	45 mg/L	2/Month	Grab	This limit is in effect from November through April annually.

Monitoring Requirements and Effluent Limitations					
Parameter	Limit Type	Limit and Units	Sample Frequency	Sample Type	Notes
Suspended Solids, Total	Weekly Avg	18 mg/L	2/Month	Grab	This limit is in effect from May through October annually.
Fecal Coliform	Geometric Mean	400 #/100 ml	2/Month	Grab	This limit and monitoring requirement are in effect from May through September annually.
pH Field	Daily Min	6.0 su	2/Month	Grab	
pH Field	Daily Max	9.0 su	2/Month	Grab	
Dissolved Oxygen	Daily Min	6.0 mg/L	2/Month	Grab	
Copper, Total Recoverable		µg/L	Monthly	Grab	Monthly monitoring is required in 2012.
Hardness, Total as CaCO ₃		mg/L	Monthly	Grab	Monthly monitoring is required in 2012.
Nitrogen, Ammonia (NH ₃ -N) Total	Monthly Avg	18 mg/L	Weekly	Grab	The limit takes effect on April 1, 2011. The limit is then in effect from November through April annually.
Nitrogen, Ammonia (NH ₃ -N) Total	Monthly Avg	13 mg/L	Weekly	Grab	The limit takes effect on May 1, 2011. The limit is then in effect from May through October annually.
Nitrogen, Ammonia (NH ₃ -N) Total	Weekly Avg	38 mg/L	Weekly	Grab	The limit takes effect on April 1, 2011. The limit is then in effect from November through April annually.
Chronic WET		rTU _c	See Listed Qtr(s)	24-Hr Comp	Refer to WET footnote below for testing schedule.

2.2.1.1 Average Annual Design Flow

The average annual design flow of the permittee’s wastewater treatment facility is 0.013 MGD.

2.2.1.2 Whole Effluent Toxicity (WET) Testing

Primary Control Water: Deer Tail Creek

Instream Waste Concentration (IWC): 57 %

Dilution series: At least five effluent concentrations and dual controls must be included in each test.

- **Acute:** 100, 50, 25, 12.5, 6.25% and any additional selected by the permittee.
- **Chronic:** 100, 30, 10, 3, 1% (if the IWC ≤30%) or 100, 75, 50, 25, 12.5% (if the IWC >30%) and any additional selected by the permittee.

WET Testing Frequency: Tests are required during the following quarters.

- **Acute:** None required.
- **Chronic:** April 1st – June 30, 2009; July 1st – September 30, 2010; January 1st – March 31, 2011; and October 1st – December 31, 2012.

Reporting: The permittee shall report test results on the Discharge Monitoring Report form, and also complete the "Whole Effluent Toxicity Test Report Form" (Section 6, "*State of Wisconsin Aquatic Life Toxicity Testing Methods Manual, 2nd Edition*"), for each test. The original, complete, signed version of the Whole Effluent Toxicity Test Report Form shall be sent to the Biomonitoring Coordinator, Bureau of Watershed Management, 101 S. Webster St., P.O. Box 7921, Madison, WI 53707-7921, within 45 days of test completion. The original Discharge Monitoring Report (DMR) form and one copy shall be sent to the contact and location provided on the DMR by the required deadline.

Determination of Positive Results: An acute toxicity test shall be considered positive if the Toxic Unit - Acute (TU_a) is greater than 1.0 for either species. The TU_a shall be calculated as follows: If $LC_{50} \geq 100$, then $TU_a = 1.0$. If LC_{50} is < 100 , then $TU_a = 100 \div LC_{50}$. A chronic toxicity test shall be considered positive if the Relative Toxic Unit - Chronic (rTU_c) is greater than 1.0 for either species. The rTU_c shall be calculated as follows: If $IC_{25} \geq IWC$, then $rTU_c = 1.0$. If $IC_{25} < IWC$, then $rTU_c = IWC \div IC_{25}$.

Additional Testing Requirements: Within 90 days of a test which showed positive results, the permittee shall submit the results of at least 2 retests to the Biomonitoring Coordinator on "Whole Effluent Toxicity Test Report Forms". The retests shall be completed using the same species and test methods specified for the original test (see the Standard Requirements section herein).

3 Septage Management Requirements

3.1 Sampling Point(s)

The discharge(s) shall be limited to land application for the listed sampling point(s) on Department approved land application sites, or by hauling to another permitted facility.

Sampling Point Designation	
Sampling Point Number	Sampling Point Location, WasteType/Sample Contents and Treatment Description (as applicable)
990	The facility has individual septic tanks at each structure in the village served by the treatment system. Approximately 1/3 of the septic tanks are pumped out each year. The final tanks at the treatment plant are pumped out every year.

3.2 Record Keeping Requirements and Limitations

The permittee shall comply with the following record keeping requirements and limitations.

3.2.1 Sampling Point 990 - Septic tank

3.2.1.1 System Maintenance

To ensure proper system maintenance, the accumulated solids in the septic tank(s) shall be removed regularly, consistent with the recommended removal rates in the operations and maintenance manual. The permittee shall obtain the following copies of records from the licensed septage hauler and they shall be retained for at least five years and made available to the Department on request. The records shall include: the licensed hauler used; the volume of waste pumped; dates when the waste was removed; the land application site DNR number and the method used to satisfy the pathogen and vector attraction control (injection, incorporation, or pH adjustment) requirements of ch. NR 113; Wis. Administrative Code, and/or the treatment plant where it was disposed. Winter application is not allowed.

NOTE: The contents of the septic system must be removed and disposed of by a licensed and certified septage hauler in accordance with chapter NR 113, Wis. Adm. Code. If the permittee intends to manage the septage directly then advance notice to the Department is required. The Standard Requirements section herein specifies land application requirements for septage when managed directly by the permittee.

4 Schedules of Compliance

4.1 Ammonia Effluent Limits & Facility Modifications

Required Action	Date Due
Report on Effluent Discharges: Submit a report on effluent discharges of total ammonia nitrogen with conclusions regarding compliance.	07/01/2009
Action Plan or Facility Plan Amendment: Submit an action plan or facility plan amendment for treatment facility modifications for complying with the effluent limitation(s) as needed.	10/01/2009
Plans and Specifications: Submit plans and specifications for treatment facility modifications as needed.	04/01/2010
Complete Actions: Complete actions necessary to achieve compliance with the effluent limitation(s) for ammonia nitrogen.	04/01/2011

5 Standard Requirements

NR 205, Wisconsin Administrative Code: The conditions in ss. NR 205.07(1) and NR 205.07(2), Wis. Adm. Code, are included by reference in this permit. The permittee shall comply with all of these requirements. Some of these requirements are outlined in the Standard Requirements section of this permit. Requirements not specifically outlined in the Standard Requirement section of this permit can be found in ss. NR 205.07(1) and NR 205.07(2).

5.1 Reporting and Monitoring Requirements

5.1.1 Monitoring Results

Monitoring results obtained during the previous month shall be summarized and reported on a Department Wastewater Discharge Monitoring Report. The report may require reporting of any or all of the information specified below under 'Recording of Results'. This report is to be returned to the Department no later than the date indicated on the form. When submitting a paper Discharge Monitoring Report form, the original and one copy of the Wastewater Discharge Monitoring Report Form shall be submitted to the return address printed on the form. A copy of the Wastewater Discharge Monitoring Report Form or an electronic file of the report shall be retained by the permittee.

All Wastewater Discharge Monitoring Reports submitted to the Department should be submitted using the electronic Discharge Monitoring Report system. Permittees who may be unable to submit Wastewater Discharge Monitoring Reports electronically may request approval to submit paper DMRs upon demonstration that electronic reporting is not feasible or practicable.

If the permittee monitors any pollutant more frequently than required by this permit, the results of such monitoring shall be included on the Wastewater Discharge Monitoring Report.

The permittee shall comply with all limits for each parameter regardless of monitoring frequency. For example, monthly, weekly, and/or daily limits shall be met even with monthly monitoring. The permittee may monitor more frequently than required for any parameter.

An Electronic Discharge Monitoring Report Certification sheet shall be signed and submitted with each electronic Discharge Monitoring Report submittal. This certification sheet, which is not part of the electronic report form, shall be signed by a principal executive officer, a ranking elected official or other duly authorized representative and shall be mailed to the Department at the time of submittal of the electronic Discharge Monitoring Report. The certification sheet certifies that the electronic report form is true, accurate and complete. Paper reports shall be signed by a principal executive officer, a ranking elected official, or other duly authorized representative.

5.1.2 Sampling and Testing Procedures

Sampling and laboratory testing procedures shall be performed in accordance with Chapters NR 218 and NR 219, Wis. Adm. Code and shall be performed by a laboratory certified or registered in accordance with the requirements of ch. NR 149, Wis. Adm. Code. Groundwater sample collection and analysis shall be performed in accordance with ch. NR 140, Wis. Adm. Code. The analytical methodologies used shall enable the laboratory to quantitate all substances for which monitoring is required at levels below the effluent limitation. If the required level cannot be met by any of the methods available in NR 219, Wis. Adm. Code, then the method with the lowest limit of detection shall be selected. Additional test procedures may be specified in this permit.

5.1.3 Recording of Results

The permittee shall maintain records which provide the following information for each effluent measurement or sample taken:

- the date, exact place, method and time of sampling or measurements;

- the individual who performed the sampling or measurements;
- the date the analysis was performed;
- the individual who performed the analysis;
- the analytical techniques or methods used; and
- the results of the analysis.

5.1.4 Reporting of Monitoring Results

The permittee shall use the following conventions when reporting effluent monitoring results:

- Pollutant concentrations less than the limit of detection shall be reported as < (less than) the value of the limit of detection. For example, if a substance is not detected at a detection limit of 0.1 mg/L, report the pollutant concentration as < 0.1 mg/L.
- Pollutant concentrations equal to or greater than the limit of detection, but less than the limit of quantitation, shall be reported and the limit of quantitation shall be specified.
- For the purposes of reporting a calculated result, average or a mass discharge value, the permittee may substitute a 0 (zero) for any pollutant concentration that is less than the limit of detection. However, if the effluent limitation is less than the limit of detection, the department may substitute a value other than zero for results less than the limit of detection, after considering the number of monitoring results that are greater than the limit of detection and if warranted when applying appropriate statistical techniques.

5.1.5 Compliance Maintenance Annual Reports

Compliance Maintenance Annual Reports (CMAR) shall be completed using information obtained over each calendar year regarding the wastewater conveyance and treatment system. The CMAR shall be submitted by the permittee in accordance with ch. NR 208, Wis. Adm. Code, by June 30, each year on an electronic report form provided by the Department.

In the case of a publicly owned treatment works, a resolution shall be passed by the governing body and submitted as part of the CMAR, verifying its review of the report and providing responses as required. Private owners of wastewater treatment works are not required to pass a resolution; but they must provide an Owner Statement and responses as required, as part of the CMAR submittal.

A separate CMAR certification document, that is not part of the electronic report form, shall be mailed to the Department at the time of electronic submittal of the CMAR. The CMAR certification shall be signed and submitted by an authorized representative of the permittee. The certification shall be submitted by mail. The certification shall verify the electronic report is complete, accurate and contains information from the owner's treatment works.

5.1.6 Records Retention

The permittee shall retain records of all monitoring information, including all calibration and maintenance records and all original strip chart recordings for continuous monitoring instrumentation, copies of all reports required by the permit, and records of all data used to complete the application for the permit for a period of at least 3 years from the date of the sample, measurement, report or application. All pertinent sludge information, including permit application information and other documents specified in this permit or s. NR 204.06(9), Wis. Adm. Code shall be retained for a minimum of 5 years.

5.1.7 Other Information

Where the permittee becomes aware that it failed to submit any relevant facts in a permit application or submitted incorrect information in a permit application or in any report to the Department, it shall promptly submit such facts or correct information to the Department.

5.2 System Operating Requirements

5.2.1 Noncompliance Notification

- The permittee shall report the following types of noncompliance by a telephone call to the Department's regional office within 24 hours after becoming aware of the noncompliance:
 - any noncompliance which may endanger health or the environment;
 - any violation of an effluent limitation resulting from an unanticipated bypass;
 - any violation of an effluent limitation resulting from an upset; and
 - any violation of a maximum discharge limitation for any of the pollutants listed by the Department in the permit, either for effluent or sludge.
- A written report describing the noncompliance shall also be submitted to the Department's regional office within 5 days after the permittee becomes aware of the noncompliance. On a case-by-case basis, the Department may waive the requirement for submittal of a written report within 5 days and instruct the permittee to submit the written report with the next regularly scheduled monitoring report. In either case, the written report shall contain a description of the noncompliance and its cause; the period of noncompliance, including exact dates and times; the steps taken or planned to reduce, eliminate and prevent reoccurrence of the noncompliance; and if the noncompliance has not been corrected, the length of time it is expected to continue.

NOTE: Section 292.11(2)(a), Wisconsin Statutes, requires any person who possesses or controls a hazardous substance or who causes the discharge of a hazardous substance to notify the Department of Natural Resources **immediately** of any discharge not authorized by the permit. The discharge of a hazardous substance that is not authorized by this permit or that violates this permit may be a hazardous substance spill. To report a hazardous substance spill, call DNR's 24-hour HOTLINE at **1-800-943-0003**

5.2.2 Flow Meters

Flow meters shall be calibrated annually, as per s. NR 218.06, Wis. Adm. Code.

5.2.3 Raw Grit and Screenings

All raw grit and screenings shall be disposed of at a properly licensed solid waste facility or picked up by a licensed waste hauler. If the facility or hauler are located in Wisconsin, then they shall be licensed under chs. NR 500-536, Wis. Adm. Code.

5.2.4 Sludge Management

All sludge management activities shall be conducted in compliance with ch. NR 204 "Domestic Sewage Sludge Management", Wis. Adm. Code.

5.2.5 Prohibited Wastes

Under no circumstances may the introduction of wastes prohibited by s. NR 211.10, Wis. Adm. Code, be allowed into the waste treatment system. Prohibited wastes include those:

- which create a fire or explosion hazard in the treatment work;
- which will cause corrosive structural damage to the treatment work;
- solid or viscous substances in amounts which cause obstructions to the flow in sewers or interference with the proper operation of the treatment work;
- wastewaters at a flow rate or pollutant loading which are excessive over relatively short time periods so as to cause a loss of treatment efficiency; and
- changes in discharge volume or composition from contributing industries which overload the treatment works or cause a loss of treatment efficiency.

5.2.6 Unscheduled Bypassing

Any unscheduled bypass or overflow of wastewater at the treatment works or from the collection system is prohibited, and the Department may take enforcement action against a permittee for such occurrences under s. 283.89, Wis. Stats., unless:

- The bypass was unavoidable to prevent loss of life, personal injury, or severe property damage;
- There were no feasible alternatives to the bypass, such as the use of auxiliary treatment facilities, retention of untreated wastes, or maintenance during normal periods of equipment downtime. This condition is not satisfied if adequate back-up equipment should have been installed in the exercise of reasonable engineering judgment to prevent a bypass which occurred during normal periods of equipment downtime or preventive maintenance; and
- The permittee notified the Department as required in this Section.

Whenever there is an unscheduled bypass or overflow occurrence at the treatment works or from the collection system, the permittee shall notify the Department within 24 hours of initiation of the bypass or overflow occurrence by telephoning the wastewater staff in the regional office as soon as reasonably possible (FAX, email or voice mail, if staff are unavailable).

In addition, the permittee shall within 5 days of conclusion of the bypass or overflow occurrence report the following information to the Department in writing:

- Reason the bypass or overflow occurred, or explanation of other contributing circumstances that resulted in the overflow event. If the overflow or bypass is associated with wet weather, provide data on the amount and duration of the rainfall or snow melt for each separate event.
- Date the bypass or overflow occurred.
- Location where the bypass or overflow occurred.
- Duration of the bypass or overflow and estimated wastewater volume discharged.
- Steps taken or the proposed corrective action planned to prevent similar future occurrences.
- Any other information the permittee believes is relevant.

5.2.7 Scheduled Bypassing

Any construction or normal maintenance which results in a bypass of wastewater from a treatment system is prohibited unless authorized by the Department in writing. If the Department determines that there is significant public interest in the proposed action, the Department may schedule a public hearing or notice a proposal to approve the bypass. Each request shall specify the following minimum information:

- proposed date of bypass;
- estimated duration of the bypass;

- estimated volume of the bypass;
- alternatives to bypassing; and
- measures to mitigate environmental harm caused by the bypass.

5.2.8 Proper Operation and Maintenance

The permittee shall at all times properly operate and maintain all facilities and systems of treatment and control which are installed or used by the permittee to achieve compliance with the conditions of this permit. The wastewater treatment facility shall be under the direct supervision of a state certified operator as required in s. NR 108.06(2), Wis. Adm. Code. Proper operation and maintenance includes effective performance, adequate funding, adequate operator staffing and training as required in ch. NR 114, Wis. Adm. Code, and adequate laboratory and process controls, including appropriate quality assurance procedures. This provision requires the operation of back-up or auxiliary facilities or similar systems only when necessary to achieve compliance with the conditions of the permit.

5.3 Surface Water Requirements

5.3.1 Permittee-Determined Limit of Quantitation Incorporated into this Permit

For pollutants with water quality-based effluent limits below the Limit of Quantitation (LOQ) in this permit, the LOQ calculated by the permittee and reported on the Discharge Monitoring Reports (DMRs) is incorporated by reference into this permit. The LOQ shall be reported on the DMRs, shall be the lowest quantifiable level practicable, and shall be no greater than the minimum level (ML) specified in or approved under 40 CFR Part 136 for the pollutant at the time this permit was issued, unless this permit specifies a higher LOQ.

5.3.2 Appropriate Formulas for Effluent Calculations

The permittee shall use the following formulas for calculating effluent results to determine compliance with average limits and mass limits:

Weekly/Monthly average concentration = the sum of all daily results for that week/month, divided by the number of results during that time period.

Weekly Average Mass Discharge (lbs/day): Daily mass = daily concentration (mg/L) x daily flow (MGD) x 8.34, then average the daily mass values for the week.

Monthly Average Mass Discharge (lbs/day): Daily mass = daily concentration (mg/L) x daily flow (MGD) x 8.34, then average the daily mass values for the month.

5.3.3 Visible Foam or Floating Solids

There shall be no discharge of floating solids or visible foam in other than trace amounts.

5.3.4 Percent Removal

During any 30 consecutive days, the average effluent concentrations of BOD₅ and of total suspended solids shall not exceed 15% of the average influent concentrations, respectively. This requirement does not apply to removal of total suspended solids if the permittee operates a lagoon system and has received a variance for suspended solids granted under NR 210.07(2), Wis. Adm. Code.

5.3.5 Fecal Coliforms

The limit for fecal coliforms shall be expressed as a monthly geometric mean.

5.3.6 Seasonal Disinfection

Disinfection shall be provided from May 1 through September 30 of each year. Monitoring requirements and the limitation for fecal coliforms apply only during the period in which disinfection is required. Whenever chlorine is used for disinfection or other uses, the limitations and monitoring requirements for residual chlorine shall apply. A dechlorination process shall be in operation whenever chlorine is used.

5.3.7 Applicability of Alternative Wet Weather Mass Limitations

- An alternative wet weather mass limitation applies when:
 - The applicable mass limitation (based on annual average design flow) is exceeded; and
 - The permittee demonstrates to the satisfaction of the Department that the discharge exceedance is caused by and occurs during a wet weather event. For the purposes of this demonstration, a wet weather event occurs during and immediately following periods of precipitation or snowmelt, including but not limited to rain, sleet, snow, hail or melting snow during which water from the precipitation, snowmelt or elevated groundwater enters the sewerage system through infiltration or inflow, or both. The permittee shall present demonstrations to the Department by attaching them to the Wastewater Discharge Monitoring Report Form(s).

Note: In making this demonstration, the permittee may want to consider presenting a discussion of normal effluent flow rates, the effluent flow rates that resulted in the exceedance and identification of the event, including intensity and duration, which caused the high flow rates. A graph of effluent flow over time may also be helpful.

5.3.8 Whole Effluent Toxicity (WET) Monitoring Requirements

In order to determine the potential impact of the discharge on aquatic organisms, static-renewal toxicity tests shall be performed on the effluent in accordance with the procedures specified in the *"State of Wisconsin Aquatic Life Toxicity Testing Methods Manual, 2nd Edition"* (PUB-WT-797, November 2004) as required by NR 219.04, Table A, Wis. Adm. Code). All of the WET tests required in this permit, including any required retests, shall be conducted on the *Ceriodaphnia dubia* and fathead minnow species. Receiving water samples shall not be collected from any point in contact with the permittee's mixing zone and every attempt shall be made to avoid contact with any other discharge's mixing zone.

5.3.9 Whole Effluent Toxicity (WET) Identification and Reduction

Within 60 days of a retest which showed positive results, the permittee shall submit a written report to the Biomonitoring Coordinator, Bureau of Watershed Management, 101 S. Webster St., PO Box 7921, Madison, WI 53707-7921, which details the following:

- A description of actions the permittee has taken or will take to remove toxicity and to prevent the recurrence of toxicity;
- A description of toxicity reduction evaluation (TRE) investigations that have been or will be done to identify potential sources of toxicity, including some or all of the following actions:
 - (a) Evaluate the performance of the treatment system to identify deficiencies contributing to effluent toxicity (e.g., operational problems, chemical additives, incomplete treatment)
 - (b) Identify the compound(s) causing toxicity

- (c) Trace the compound(s) causing toxicity to their sources (e.g., industrial, commercial, domestic)
- (d) Evaluate, select, and implement methods or technologies to control effluent toxicity (e.g., in-plant or pretreatment controls, source reduction or removal)

- Where corrective actions including a TRE have not been completed, an expeditious schedule under which corrective actions will be implemented;
- If no actions have been taken, the reason for not taking action.

The permittee may also request approval from the Department to postpone additional retests in order to investigate the source(s) of toxicity. Postponed retests must be completed after toxicity is believed to have been removed.

5.4 Land Application Requirements

5.4.1 Land Application Report for Septage

Land Application Report Form 3400-55 shall be submitted by January 31, following each year septage is land applied by the permittee.

5.4.2 Other Methods of Disposal or Distribution Report for Septage

The permittee shall submit Report Form 3400-52 by January 31, following each year septage is hauled to another facility by the permittee.

5.4.3 Approval to Land Apply Septage

Septage may not be applied to a land application site by the permittee without a written site approval letter or Form 3400-122 from the Department.

5.4.4 Land Application Site Evaluation for Septage

The permittee may use land application sites provided the sites meet all applicable provisions of Wisconsin Administrative Code Chapter NR 113 and have been approved in writing by this Department. If the permittee wishes to have approval for additional sites, application shall be made using Landspreading Site Evaluation Form 3400-53. Complete information shall be submitted about each site, including plat, topographical and soil maps, aerial photograph of the site, any soil analyses results, and other information showing that the site complies with all application requirements. Land application may commence on a new site when a proposed site has been approved by the Department. The Department may issue a written notice to withdraw approval for any site that is found to be environmentally unacceptable or violates the conditions of this permit. A permittee may not land apply septage on sites that have been withdrawn by the department or that have not been approved by the department.

It is the permittee's responsibility to locate land application sites that meet the land application criteria set forth in ch. NR 113, Wis. Adm. Code.

5.4.5 Septage Hauling

If septage is hauled to another facility by the permittee, the permittee is required to submit Form 3400-52 to the Department. Information shall include the quantity of septage hauled, the name, address, phone number, contact person, and permit number of the receiving facility. Form 3400-52 shall be submitted annually by January 31 following each year septage is hauled by the permittee.

6 Summary of Reports Due

FOR INFORMATIONAL PURPOSES ONLY

Description	Date	Page
Ammonia Effluent Limits & Facility Modifications -Report on Effluent Discharges	July 1, 2009	7
Ammonia Effluent Limits & Facility Modifications -Action Plan or Facility Plan Amendment	October 1, 2009	7
Ammonia Effluent Limits & Facility Modifications -Plans and Specifications	April 1, 2010	7
Ammonia Effluent Limits & Facility Modifications -Complete Actions	April 1, 2011	7
Compliance Maintenance Annual Reports (CMAR)	by June 30, each year	8
Land Application Report Form 3400-55	by January 31, following each year septage is land applied by the permittee	13
Report Form 3400-52	by January 31, following each year septage is hauled to another facility by the permittee	13
Wastewater Discharge Monitoring Report	no later than the date indicated on the form	7

Report forms shall be submitted to the address printed on the report form. Any facility plans or plans and specifications for municipal, industrial, industrial pretreatment and non industrial wastewater systems shall be submitted to the Bureau of Watershed Management, P.O. Box 7921, Madison, WI 53707-7921. All other submittals required by this permit shall be submitted to:

Northern Region - Rhinelander, 107 Sutliff Ave., Rhinelander, WI 54501-0818